

FLOODED DEEP CYCLE BATTERY

8 FS GC-HC





Series	FS	Warranty	1 Year	
Volts	olts 8		GC2	
Cells	4	Plates/Cell	13	
Terminal Type		UTL		
Included Hardware		Stainless Steel K-Lock Nut		
Size & Thread		5/16"-18		
Charge				
Charge Voltage Range		2.45-2.5 V/cell @ 25°C (77°F)		
Float Voltage Range		2.25 V/cell @ 25°C (77°F)		
Recommended Charge Current		20 A		
Maximum Charge Current		35 A		
Self-Discharge Rate		5%-10% per month at 25°C (77°F)		
Canacity				

Capacity				
Cold Crank Amps (CCA) 0°F / -18°C			547	
Marine Crank Amps (MCA) 32°F / 0°C			684	
Reserve Capacity (RC @ 25A)			329 Minutes	
Reserve Capacity (RC @ 56A)		118 Minutes		
Reserve Capacity (RC @ 75A)			82 Minutes	5
Capacity Affect by Temperature	40°C (104°F)	25°C (77°F)	0°C (32°F)	-15°C (5°F)
	105%	100%	75%	50%

Hour Rate	Capacity / AMP Hour	Current / AMPs
@ 100 Hour Rate	233 AH	2.33 A
@ 72 Hour Rate	229 AH	3.19 A
@ 50 Hour Rate	217 AH	4.33 A
@ 20 Hour Rate	182 AH	9.1 A
@ 15 Hour Rate	173 AH	11.53 A
@ 10 Hour Rate	160 AH	16.02 A
@ 8 Hour Rate	157 AH	19.57 A
@ 5 Hour Rate	144 AH	28.76 A
@ 1 Hour Rate	73 AH	72.8 A


Ampere hour capacity ratings based on specific gravity of 1.280 at 27°C (80°F). Reduce capacities 5% for specific gravity of 1.265 and 10% for 1.250.

Specifications				
SAIGLOBAL ISO 9001 Quality	Weight	29.5 kg	65 lbs	
	Length	25.9 cm	10.19"	
	Width	18.1 cm	7.13"	
	Height Inc. Term.	27.9 cm	11"	

Product measurements & weights are calculated based on sample data. Individual specifications are subject to vary due to the manufacturing process, battery components & electrolyte levels.

Electrolyte Reserve	57 mm	2.25"
Container	Polypropylene	
Cover	Polypropylene	
Handles	Top Molded Strap Bracket	ts


Cycle Life vs. Depth of Discharge



Voltage vs. Depth of Discharge

DISCHARGE	0%	25%	50%	75%	100%
20 HR AH RATE	2.10 V	2.07 V	2.00 V	1.92 V	1.75 V
10 HR AH RATE	2.10 V	2.06 V	1.98 V	1.89 V	1.75 V
3 HR AH RATE	2.10 V	2.03 V	1.95 V	1.86 V	1.75 V
1 HR AH RATE	2.10 V	2.01 V	1.93 V	1.84 V	1.75 V

Detailed Illustration



Rev.#2 | June 2021